



April 9, 2020

DVP-200009

Mr. David Jones
Air Pollution Control Officer
South Coast Air Quality Management District
21865 East Copley Drive
Diamond Bar, California 91765-4182

Subject: Monthly Report of Excess Emissions for March 2020

SCAQMD FILE # 100154

Dear Mr. Jones:

Excess emissions summaries for each boiler for March 2020 are attached.

Emission concentration limits (ppm) do not apply during the normal start up and shut down conditions for each boiler. Thus, exceedances within the permit limits during start up and shut down, as defined in the amendment, are not applicable and as such not reportable.

Please call if you have any questions or comments. I can be reached at (760) 262-1653.

Sincerely,

A handwritten signature in black ink, appearing to read "Philip Jones".

Philip Jones

Interim Plant Manager



Page 2

encl

cc:

Chief, Stationary Source Division

California Air Resources Board

P.O. Box 2815

Sacramento, CA 95814

Director, Air Management Division

Attention: Air-5

U.S. Environmental Protection Agency

75 Hawthorne Street

San Francisco, CA 94105-3901

DESERT VIEW POWER PLANT EXCESS EMISSIONS REPORT

BOILER #1
March 2020

Hours Operated: 657 hrs

Boiler Number	Quarterly Report Code	Excess Emission number	Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
						Average Value	Maximum Value	Permit Limit	
			CEMS			CEMS			CEMS
			3/6/2020	Nox ppm@3%	1				CEM taken out of service for maintenance.
			3/29/2020	Nox ppm@3%	10				CEM taken out of service for maintenance.
			3/31/2020	Nox ppm@3%	7				CEM taken out of service for maintenance.
			3/6/2020	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
			3/29/2020	Nox lb/mmbtu	10				CEM taken out of service for maintenance.
			3/31/2020	Nox lb/mmbtu	7				CEM taken out of service for maintenance.
			3/6/2020	Nox lb/hr	1				CEM taken out of service for maintenance.
			3/29/2020	Nox lb/hr	14				CEM taken out of service for maintenance.
			3/31/2020	Nox lb/hr	4				CEM taken out of service for maintenance.
			3/6/2020	SO2 ppm@3%	1				CEM taken out of service for maintenance.
			3/29/2020	SO2 ppm@3%	10				CEM taken out of service for maintenance.
			3/31/2020	SO2 ppm@3%	7				CEM taken out of service for maintenance.
			3/6/2020	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
			3/29/2020	SO2 lb/mmbtu	10				CEM taken out of service for maintenance.
			3/31/2020	SO2 lb/mmbtu	7				CEM taken out of service for maintenance.
			3/6/2020	SO2 lb/hr	1				CEM taken out of service for maintenance.
			3/29/2020	SO2 lb/hr	14				CEM taken out of service for maintenance.
			3/31/2020	SO2 lb/hr	4				CEM taken out of service for maintenance.
			3/6/2020	CO ppm @3% O2	1				CEM taken out of service for maintenance.
			3/29/2020	CO ppm @3% O2	14				CEM taken out of service for maintenance.
			3/31/2020	CO ppm @3% O2	7				CEM taken out of service for maintenance.
			3/6/2020	CO lb/hr	1				CEM taken out of service for maintenance.
			3/29/2020	CO lb/hr	18				CEM taken out of service for maintenance.
			3/31/2020	CO lb/hr	4				CEM taken out of service for maintenance.

NOTE:

- The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

DESERT VIEW POWER PLANT EXCESS EMISSIONS REPORT

BOILER #2
March 2020

Hours Operated: 716 hrs

Boiler Number	Quarterly Report Code	Excess Emission number	Date	Limit Exceeded	Duration (hrs)	Reading at 3% O2			Comments
						Average Value	Maximum Value	Permit Limit	
			CEMS			CEMS			CEMS
			3/6/2020	Nox ppm@3%	1				CEM taken out of service for maintenance.
			3/12/2020	Nox ppm@3%	3				CEM taken out of service for maintenance.
			3/13/2020	Nox ppm@3%	3				CEM taken out of service for maintenance.
			3/29/2020	Nox ppm@3%	2				CEM taken out of service for maintenance.
			3/6/2020	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
			3/12/2020	Nox lb/mmbtu	3				CEM taken out of service for maintenance.
			3/13/2020	Nox lb/mmbtu	3				CEM taken out of service for maintenance.
			3/29/2020	Nox lb/mmbtu	2				CEM taken out of service for maintenance.
			3/6/2020	Nox lb/hr	1				CEM taken out of service for maintenance.
			3/12/2020	Nox lb/hr	3				CEM taken out of service for maintenance.
			3/6/2020	SO2 ppm@3%	1				CEM taken out of service for maintenance.
			3/12/2020	SO2 ppm@3%	3				CEM taken out of service for maintenance.
			3/13/2020	SO2 ppm@3%	3				CEM taken out of service for maintenance.
			3/29/2020	SO2 ppm@3%	2				CEM taken out of service for maintenance.
			3/6/2020	SO2 lb/mmbtu	1				CEM taken out of service for maintenance.
			3/12/2020	SO2 lb/mmbtu	3				CEM taken out of service for maintenance.
			3/13/2020	SO2 lb/mmbtu	3				CEM taken out of service for maintenance.
			3/29/2020	SO2 lb/mmbtu	2				CEM taken out of service for maintenance.
			3/6/2020	SO2 lb/hr	1				CEM taken out of service for maintenance.
			3/12/2020	SO2 lb/hr	3				CEM taken out of service for maintenance.
			3/6/2020	CO ppm @3% O2	1				CEM taken out of service for maintenance.
			3/12/2020	CO ppm @3% O2	4				CEM taken out of service for maintenance.
			3/13/2020	CO ppm @3% O2	5				CEM taken out of service for maintenance.
			3/29/2020	CO ppm @3% O2	3				CEM taken out of service for maintenance.
			3/6/2020	CO lb/hr	1				CEM taken out of service for maintenance.
			3/12/2020	CO lb/hr	4				CEM taken out of service for maintenance.
			3/13/2020	CO lb/hr	2				CEM taken out of service for maintenance.
			3/29/2020	CO lb/hr	1				CEM taken out of service for maintenance.

NOTE:

- The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

STACK
March 2020

[illegible]

1. The term ALL is used in the Limit Exceeded column to indicate the following:
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)